



Hampshire County Council

*Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD*

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

<i>Enquiries to</i>	Santiago Manzanero	<i>My reference</i>	SWM/2019/0615
<i>Direct Line</i>	01962 846777	<i>Your reference</i>	APP/19/00703
<i>Date</i>	20 November 2019	<i>Email</i>	SWM.consultee@hants.gov.uk

Dear Sir/Madam,

Part-demolition of Building 1000 and associated works; the erection of new flexible use industrial units; and a new parking layout with associated works to layout and access at Langstone Technology Park, 2B Langstone Road, Havant, PO9 1SA.

Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application in our role as statutory consultee on surface water drainage for major developments.

In order to assist applicants in providing the correct information to their Local Planning Authority for planning permission, Hampshire County Council has set out the information it requires to provide a substantive response at <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning>

The County Council has reviewed the following documents relating to the above application:

- DRAINAGE STRATEGY GENERAL ARRANGEMENT SHEETS 1 & 2; Job No. 8/1982; Drawing No. 4400; Revision P2; dated 17/10/2019.
- INDICATIVE DRAINAGE DETAILS SHEETS 1 & 2; Job No. 8/1982; Drawing No. 400410; Revision P1; dated: 18/10/2019.
- SUMMARY OF EXISTING SURFACE WATER DRAINAGE FOR PROPOSED DEVELOPMENT AREAS; Drawing No. 4600; Revision P1; dated: 25/10/2019.
- Calculation Package and Design Philosophy for Drainage; Ref: 8/1982; Revision B; dated: 25th October 2019.

*Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI*

Following our formal response to this planning application dated 20 August 2018, we received additional information on the 15 November 2019 including detailed hydraulic calculations together with the detailed drainage drawings. The additional information has addressed our previous concerns regarding surface water management and local flood risk.

Therefore, the County council as the Lead Local Flood Authority (LLFA) has **no objection** to the proposals.

We would also recommend that the applicant is directed to our website <http://www3.hants.gov.uk/flooding/hampshireflooding/drainagesystems.htm> for further information on recommended surface water drainage techniques.

Please note that Hampshire County Council as Lead Local Flood Authority will not comment on the fluvial systems as these are outside our remit.

As a statutory consultee, the County Council has a duty to respond to consultations within **21 days**. The 21-day period will not begin until we have received sufficient information to enable us to provide a meaningful response.

Please ensure all data is sent to us via the relevant Local Planning Authority.

For guidance on providing the correct information, we recommend you use our **Surface Water Management Pre-application service** which provides clear guidance on what is required for us to recommend that planning permission is granted and consider the works as best practise. For full details, please visit: <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning> and click on [pre-application advice request form](#).

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,



Flood and Water Management Team
Economy, Transport & Environment Department,
Hampshire County Council, 1st Floor, EII Court West,
The Castle, Winchester, Hampshire SO23 8UD
Web: <http://www3.hants.gov.uk/flooding/watercourses.htm>

General guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

Works in relation to ordinary watercourses

*PLEASE NOTE: If the proposals include works to an ordinary watercourse, under the Land Drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.***

Information on ordinary watercourse consenting can be found at the following link <http://www3.hants.gov.uk/flooding/hampshireflooding/watercourses.htm>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

*For guidance on providing the correct information, we recommend you use our **Ordinary Watercourse Consents Pre-application service** and help avoid delays occurring at the formal application stage. A Pre-application service for Ordinary Watercourse Consents is available, allowing consents to go through in a smoother, often more timely manner. For full information please visit:*

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/WatercoursePreApplication>