

Clark, Jacky

From: Peter Galloway <pgparchitects@yahoo.co.uk>
Sent: 19 November 2019 16:55
To: Clark, Jacky
Subject: 10A The Pallant
Attachments: LS01.pdf; LS02.pdf

Hi Jacky

Re:Landscape Comments

Planning Application APP/19/01030 10A The Pallant, Havant, PO9 1BE Demolition of existing building on 10A, The Pallant and adjacent existing building remaining to the rear of 11 East Street; Erection of 2No. 3 bed Town Houses , plus 1No. 1 bed flat and 1No. 2bed maisonette.

1. The soft landscaping proposals of solely grass is not deemed acceptable, there is insufficient light for the grass to survive. We require a soft landscaping scheme which consists of shrubs, herbaceous planting, trees, bulbs etc. that are appropriate for the proposed location and conditions.

2. The development is situated within the heart of the conservation area of Snt faiths as such the building façade and materials specifications needs to reflect the existing character. The use of cream render is not deemed acceptable and we would want to see a weathered red brick with grey brick detailing to reflect the historical character. - REFER PREVIOUS COMMENTS

3. The use of Saxon paving as a border/trim to the car parking area is not deemed acceptable as it will fail should any vehicle over run the car parking bay. All the hard landscaping within and abutting the car parking areas should be appropriate for vehicular traffic. We would recommend the used of setts or cobbles - SEE BELOW

4. We require further details submitted in relation to the raised bed planters consisting of elevations and material specification.

5. Details of the lighting strategy need to be provided.

We require the following drawings to be submitted for comment:

6. A soft landscape scheme requiring submission of fully annotated plans at sufficient scale to identify species of individually planted trees, shrubs, hedges, marginal, bulbs and any areas of turfing / seeding. Planting areas should show the locations of different single species groups in relation to one another, and the locations of any individual specimen shrubs. Other information shall include plant specification schedules, comprising plant size, number and density.

DRAWING NOS. LS01 & LS02 ATTACHED SHOWS PLANTING AREA D AS THE ONLY RELEVANT AREA TO LANDSCAPED IN THIS APPLICATION - OTHER AREAS RELATE TO DWELLINGS AND WILL BE HANDLED BY THE OCCUPANTS AS THEIR RESPONSIBILITY - note: ITEM 5 DOES NOT RELATE TO THIS APPLICATION

7. Hard landscape details requiring submission of fully annotated plans at sufficient scale that comprise the proposed range of coloured and textured surfacing treatments, which identify:

8. hard surfacing material type / product reference and colour 9. laying bond 10. edging or kerb detail / type 12. Boundary details requiring submission of fully annotated plans at sufficient scale showing the locations of existing, retained and proposed new boundary treatments, with scaled elevation drawings to show height, design, materials, type and colour of proposed new.

ALL OF THESE DETAILS ARE NOW INDICATED ON DRAWING NOS. LS01 & LS02 ATTACHED

Should you require any further details at this stage please advise.

Peter Galloway RIBA