

Dear Daphney

I am unable to write comments on the consultation form as it says time has elapsed

I would make the following comments:

1. Possible Public Sewer within 3m of Plot 3 (see map below) consult SWS
2. Compliance with Approved Document B Section 5 Fire Authority access (turning facility)
3. Solid waste storage bins are not shown and should comply with Approved Document H
4. Plot 2 shows room in the roof therefore protected route down stairs needed. Plots 1 & 3 are only 2 Bed not 3 noted wrong on plan
5. Building Regulation consent will be needed for this work

Sewer map



Regards

Colin Adams BSc(Hons) MRICS FRACS
Senior Building Control Surveyor T: 02392 446574 or Admin 02392 446571
Building Control
Havant Borough Council, Public Service Plaza, Civic Centre Road, Havant PO9 2AX