

Afternoon Lesley

Please accept this email as confirmation that we recommend planning permission is granted providing the following condition is attached,

The rating level of the noise emitted from the plant installed as part of this application shall not exceed the existing background sound levels determined to be 39 dB LA90,1hour during the day time (07:00 – 23:00 hours) and 28 dB LA90,15minutes during the night time (23:00 – 07:00 hours). The noise levels shall be determined at the nearest residential property as identified in the noise report submitted by Noise Solution Ltd (Project Ref: 88660, Rev:01, Date: 29/7/19, Revised: 19/6/2020). The measurements and assessment shall be made according to British Standard 4142:2014+A1:2009.

Regards

Helen Le-Vallee
Environmental Health Officer
Direct Dial: 01730 234302



East Hampshire District Council
Penns Place, Petersfield
GU31 4EX

www.easthants.gov.uk
www.facebook.com/easthantsdc
www.twitter.com/easthantsdc

Your privacy matters, go to www.easthants.gov.uk/privacy-policy



Havant Borough Council
Public Service Plaza, Civic Centre
PO9 2AX

www.havant.gov.uk
www.facebook.com/havantborough
www.twitter.com/havantborough

Your privacy matters, go to www.havant.gov.uk/privacy-policy