

Consultee Comments for Planning Application APP/19/00802

Application Summary

Application Number: APP/19/00802

Address: The Langstone Hotel, Northney Road, Hayling Island, PO11 0NQ

Proposal: Erection of modular clad portable building for health and wellness activities.

Case Officer: Tina Pickup

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

The fire strategy for the building will need to be resolved, as the current layout would not comply with the means of escape requirements set in Approved Document B. Further fire exits maybe required that may alter the external appearance.