

Consultee Comments for Planning Application APP/19/01046

Application Summary

Application Number: APP/19/01046

Address: 16 Park Crescent, Emsworth, PO10 7NT

Proposal: Proposed single storey side and rear extension following removal of existing porch and conservatory.

Case Officer: Lesley Wells

Consultee Details

Name: Ms Arboricultural Officer

Address: east hampshire district council, penns place, petersfield gu31 4ex

Email: maria.stewart@easthants.gov.uk

On Behalf Of: Arboriculturalist

Comments

The current method statement is not adequate for this site. Protective fencing wont be effective given the proximity to the tree and the ability to build. Ground protection will be the most suitable method of protection. I will therefore require a more detailed, site specific method statement and a Tree Protection Plan which is to scale. It should also be noted that the off site Lime tree next to the Oak tree should also be considered as part of this application.