



Department of Planning and Development  
Havant Borough Council  
Public Service Plaza  
Civic Centre Road  
Havant  
Hampshire  
PO9 2AX

Your ref  
APP/20/00245

Our ref  
PLAN-032412

Date  
10/04/2020

Contact  
Tel 0330 303 0119

Dear Sir/Madam,

**Proposal:** Single storey side extension and carport.

**Site:** APP/20/00245: - 14 Cherrywood Gardens, Hayling Island, PO11 9DE.

Thank you for your letter dated 24/03/2020.

Please find attached a plan of the sewer records showing the approximate position of a public foul sewer within the site. The exact position of the public foul sewer must be determined on site by the applicant before the layout of the proposed development is finalised.

Please note:

- No development or tree planting should be carried out within 3 metres of the external edge of the public gravity sewer without consent from Southern Water.
- No soakaway, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of a public sewer.
- All existing infrastructure should be protected during the course of construction works.

Furthermore, it is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.



Southern Water requires a formal application for any new connection to the public sewer to be made by the applicant or developer. We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link [southernwater.co.uk/infrastructure-charges](https://southernwater.co.uk/infrastructure-charges)

The disposal of surface water from this development shall follow the hierarchy within Part H3 of Building Regulations:

- a) An adequate soakaway or some other adequate infiltration system.
- b) A water course.
- c) Where neither of the above is practicable: a sewer.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: [southernwater.co.uk](https://southernwater.co.uk) or by email at: [developerservices@southernwater.co.uk](mailto:developerservices@southernwater.co.uk)

Yours faithfully,



Joff Edevane  
Growth Planning Lead  
**Business Channels**