

Consultee Comments for Planning Application APP/20/00283

Application Summary

Application Number: APP/20/00283

Address: Imperial Palace, 37 Belmont Grove, Havant, PO9 3PT

Proposal: Installation of plant equipment associated with proposed foodstore within external enclosure at the rear, northern side of the building.

Case Officer: Lesley Wells

Consultee Details

Name: Consultee Environmental Health (Environment Team)

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: EHEnvironment@havant.gov.uk

On Behalf Of: Environmental Health Manager, Community Group

Comments

Thank you for consulting the Environmental Protection Team on this planning application. Please note these comments relate to noise only.

Please provide the manufacturer's data for the Hubbard Refrigeration Pack and also the Refrigeration Condenser (Kelvion/GF-SA102F4H-063) showing the octave band noise data for these pieces of plant as this has not been included within the acoustic report.

Thank you

Helen Le-Vallee

Environmental Health Officer

Environmental Protection Team (Havant BC)