

From: rob.sinclair@sinclairdalby.co.uk

Sent: 08 April 2020 09:09

To: Haywood, Daphney <

Subject: Re: Proposed Telecoms Installation on Eagle Avenue, WaterlooVille VF 17445 application ref APP/20/00150

Hi Daphney,

I have just chased up the tree pits info and would hope to have this back to you asap.

I can confirm that digging in the root protection areas will be carried out by hand.

I can confirm that should a substantial root, being any root of greater than 25mm diameter, be located the exact position of any proposed tree will be decided in consultation with the Landscape Architect prior to planting.

Kind regards

Rob Sinclair
Director
Sinclair Dalby Limited