

ABMH		Page 1
1 The Grove Felpham West Sussex PO22 7EY	Woodcroft SW Design	
Date 07/08/2019 12:52 File FC2789 Woodcroft- sw de...	Designed by mh Checked by	
Micro Drainage	Network 2017.1.2	

Summary of Results for 15 minute 1 year Winter (Storm)

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
 Analysis Timestep Fine Inertia Status OFF
 DTS Status ON

PN	US/MH Name	Water Surcharged Flooded			Pipe		Status
		Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	
1.000	SWS13	67.175	-0.075	0.000	0.47	7.8	OK
1.001	SWS12	66.975	-0.099	0.000	0.24	9.7	OK
1.002	SWS11	65.696	-0.179	0.000	0.09	9.8	OK
2.000	SWS10.1	65.370	-0.155	0.000	0.20	14.1	OK
1.003	SWS10	64.748	-0.193	0.000	0.27	27.4	OK
1.004	SWS9	64.477	-0.177	0.000	0.36	27.1	OK
1.005	SWS8	63.129	-0.981	0.000	0.05	40.4	OK
3.000	Dummy	62.933	-0.225	0.000	0.00	0.0	OK
3.001	SW7.3	62.929	-0.225	0.000	0.00	0.0	OK
3.002	SW7.1	63.103	-0.772	0.000	0.00	0.0 1.9	OK
1.006	SWS7	63.104	-0.966	0.000	0.04	30.1	OK
1.007	SWS6	63.097	-0.963	0.000	0.05	28.4	OK
4.000	SWS5.1	65.292	-0.183	0.000	0.08	8.7	OK
1.008	SWS5	63.089	-0.957	0.000	0.04	36.7	OK
1.009	SWS4	63.080	-0.728	0.000	0.06	41.5	OK
1.010	SWS3	63.072	0.020	0.000	0.44	27.8	SURCHARGED
1.011	SWS2	62.798	-0.190	0.000	0.29	27.8	OK