

Consultee Comments for Planning Application APP/19/00950

Application Summary

Application Number: APP/19/00950

Address: Garage blocks, Willowdene Close, Havant

Proposal: Proposed change of use and conversion and extension of existing garage block A to create 1No. 3 bedroom detached dwelling with associated car parking and bike and bin storage, reconfiguration of existing vehicular access, new gate and boundary wall, and associated works to garage block B.

Case Officer: Tina Pickup

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

Fire authority access to be confirmed - it is currently unclear if the existing access will be used, if the existing surface is suitable or if the access will be altered.

Bin storage to be provided.

Part of the extension work on the south-east elevation could be within 3m of a Public Foul Sewer. Location should be checked on site and a consultation with Southern Water to be undertaken if the sewer is within 3m.