

ABMH		Page 1
1 The Grove Felpham West Sussex PO22 7EY	Woodcroft SW Design	
Date 07/08/2019 12:47 File FC2789 Woodcroft- sw de...	Designed by mh Checked by	
Micro Drainage	Network 2017.1.2	

Summary of Results for 15 minute 1 year Summer (Storm)

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
 Analysis Timestep Fine Inertia Status OFF
 DTS Status ON

PN	US/MH Name	Water Surcharged Flooded			Pipe		Status
		Level (m)	Depth (m)	Volume (m³)	Flow / Cap. (l/s)	Flow (l/s)	
1.000	SWS13	67.187	-0.063	0.000	0.54	9.0	OK
1.001	SWS12	66.980	-0.094	0.000	0.27	10.8	OK
1.002	SWS11	65.701	-0.174	0.000	0.11	11.2	OK
2.000	SWS10.1	65.380	-0.145	0.000	0.24	16.5	OK
1.003	SWS10	64.759	-0.182	0.000	0.31	30.9	OK
1.004	SWS9	64.485	-0.169	0.000	0.40	30.9	OK
1.005	SWS8	63.120	-0.990	0.000	0.05	41.6	OK
3.000	Dummy	62.933	-0.225	0.000	0.00	0.0	OK
3.001	SW7.3	62.929	-0.225	0.000	0.00	0.0	OK
3.002	SW7.1	63.089	-0.786	0.000	0.00 0.0	1.8	OK
1.006	SWS7	63.089	-0.981	0.000	0.04	27.5	OK
1.007	SWS6	63.082	-0.978	0.000	0.05	26.1	OK
4.000	SWS5.1	65.298	-0.177	0.000	0.10	10.6	OK
1.008	SWS5	63.071	-0.975	0.000	0.04	33.6	OK
1.009	SWS4	63.058	-0.750	0.000	0.06	38.4	OK
1.010	SWS3	63.049	-0.003	0.000	0.42	26.6	OK
1.011	SWS2	62.795	-0.193	0.000	0.28	26.6	OK