



HAMPSHIRE

CONSTABULARY

Gosport NPT Neighbourhood Police Office

Town Hall
High Street
Gosport
Hampshire
PO12 1EB

Telephone

101

Direct Dial

023 8047 8566

Fax

01962 874201

Text Relay

18001 101

Email Address

stuart.york.17529@hampshire.pnn.police.uk

Miss S. Donophy
Planning Services
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Our ref: app/19
Your ref: APP/19/00853

6th November 2019

Dear Miss Donophy,

PURBROOK CRICKET CLUB, PURBROOK HEATH ROAD, PURBROOK, WATERLOOVILLE, PO7 5RU

Thank you for your email of the 5th November 2019 and the opportunity to comment upon the application. Having considered the application I have the following comments to make with reference to crime prevention.

Purbrook Heath Recreation Ground is a fairly isolated place, with very little natural surveillance from outside the recreation ground. There is no lighting to provide for natural surveillance during the hours of darkness.

The proposed building is to be located in the corner of the area behind a hedge, with a grass bank on two sides. The building must be positioned to ensure that access to the roof cannot be gained using the nearby grass banks.

The rain water down pipes must be of robust construction, and should not create a handhold that would facilitate access to the roof.

To provide for the security of the building external doors to the following (minimum) standards should be fitted:

- The pedestrian access door should be third party certificated to LPS 1175 SR2.



www.hampshire.police.uk

Deaf? Non-emergency text **07781 480999**

For crime and community information www.hampshirealert.co.uk



- Both roller shutter doors should be third party certificated to LPS 1175 SR2. Consideration will have to be given as to how these doors are to be secured in the closed position, as any exposed locking system can be attacked.

If the building is to have a mains power supply consideration should be given to the installation of a monitored intruder alarm system. A cloaking device could be incorporated into the system if the situation demanded.

The design and access statement advises that the sight screens can be secured to this building during the non-playing months. If the cricket screens are to be fixed to the building it is important that they cannot be used to access the roof.

A gate is to be fitted to provide for access to the site. The gate should be of robust construction, fitted with appropriate locking hardware. Suitable fittings must be provided to prevent the gate from being lifted off of its hinges.

If I can be of any further assistance please do not hesitate to contact me.

Yours sincerely,

S York
Designing Out Crime Officer

DISCLAIMER

This survey is based on information supplied by yourself and the current crime trends. I can only give a view on what measures might reduce the risk of crime and there can be no guarantee that the measures will prevent crime. The advice is given free with no intention of creating a contract. Neither the Home Office or Hampshire Constabulary take any other legal responsibility for the advice given.



www.hampshire.police.uk

Deaf? Non-emergency text **07781 480999**

For crime and community information www.hampshirealert.co.uk

