



Hampshire County Council

*Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD*

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

<i>Enquiries to</i>	Sarah Reghif	<i>My reference</i>	SWM/2019/0528
<i>Direct Line</i>	01962 846730	<i>Your reference</i>	APP/13/00804
<i>Date</i>	30 March 2020	<i>Email</i>	SWM.consultee@hants.gov.uk

Dear Sir/Madam,

Development of 288 residential units comprising 9 x one bedroom, 110 x two bedroom, 124 x three bedroom and 45 x four bedroom, retention of existing farmhouse, new access road from Eagle Avenue, internal access roads, associated car parking, open space and landscaping and including works to trees under TPO 1931 (Approved 5 May 2015). Request to discharge condition 26 and partially discharge condition 5 (3.1.17). Request to Discharge Condition No.s 2, 3, 6 and 8 (21.02.17). Request to partially discharge condition 19 (28.2.17). Request to discharge condition No. 2 (24.08.17). Request to Discharge Condition Nos. 2 and 5 (21.02.18). Request to discharge conditions 3,4, 6, 7, 8, 9, 10, 11, 12, 14, 15, 16, 17, 18, 19, 25, 29, 30, 31 and 33 (3.04.18). Request to Discharge Condition No/s 3, 4, 6, 7, 8, 9, 10, 11, 12, 14, 16, 17 & 18 (Residential Phase 2) (06.06.2019). at Woodcroft Farm Development Site, Woodcroft Lane, Waterlooville

Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application in our role as statutory consultee on surface water drainage for major developments.

In order to assist applicants in providing the correct information to their Local Planning Authority for planning permission, Hampshire County Council has set out the information it requires to provide a substantive response at <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning>

The County Council has reviewed the following documents relating to the above application:

- Management Company memorandum dated 23 July 2018
- Gateway Maintenance Specifications

*Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI*

- Drainage Strategy (off site drainage) revC
- Section 38 Adoption Plan ref: 17-110/2227 C
- Southern Water correspondence ref: PLAN-032073

The additional information provided covers the points highlighted previously and as such, **we have no objection to the discharge of Condition 16** for the off site works.

As a statutory consultee, the County Council has a duty to respond to consultations within **21 days**. The 21 day period will not begin until we have received sufficient information to enable us to provide a meaningful response.

Please ensure all data is sent to us via the relevant Local Planning Authority.

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,



Flood and Water Management Team
 Economy, Transport & Environment Department,
 Hampshire County Council, 1st Floor, Ell Court West,
 The Castle, Winchester, Hampshire SO23 8UD
 Web: <http://www3.hants.gov.uk/flooding/watercourses.htm>

General guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their

own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

Works in relation to ordinary watercourses

*PLEASE NOTE: If the proposals include works to an ordinary watercourse, under the Land Drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.***

Information on ordinary watercourse consenting can be found at the following link <http://www3.hants.gov.uk/flooding/hampshireflooding/watercourses.htm>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

For guidance on providing the correct information, we recommend you use our **Ordinary Watercourse Consents Pre-application service** and help avoid delays occurring at the formal application stage. A Pre-application service for Ordinary Watercourse Consents is available, allowing consents to go through in a smoother, often more timely manner. For full information please visit:

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/WatercoursePreApplication>