

Consultee Comments for Planning Application APP/19/00750

Application Summary

Application Number: APP/19/00750

Address: 8 Homewell, Havant, PO9 1EE

Proposal: Demolition of existing outbuilding and erection of single storey pitched roof rear extension.(16.10.19). Request to discharge condition 3 (26.11.19).

Case Officer: Sascha Haigh

Consultee Details

Name: Consultee Heritage Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: Havant.Heritage@havant.gov.uk

On Behalf Of: Conservation Officer

Comments

Heritage Team Leader - Having reviewed the details and samples submitted I can confirm I have no objection to the slate and conservation roof light that is proposed. However, I cannot support the use of Cedral Board C06 'Grey Green' for the walls. The application was clear when submitted that dark stained waney edged timber cladding was going to be used which would be more in keeping with the style of the property.