

Consultee Comments for Planning Application APP/19/00619

Application Summary

Application Number: APP/19/00619

Address: 39 Vian Road, Waterlooville, PO7 5TW

Proposal: Demolition of existing extension at No.39 and construction of 1No. 2 bed dwelling with parking.

Case Officer: Lesley Wells

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

The proposed building will be within 3m of a foul water public sewer. A consultation should be carried out with Southern Water.

No other adverse comments