

Consultee Comments for Planning Application APP/19/01193

Application Summary

Application Number: APP/19/01193

Address: Sir George Staunton Country Park, Middle Park Way, Havant, PO9 5HB

Proposal: Hampshire County Council Listed Building application (HCC reference PLAN/WJA/HVR002) relating to alteration and repair works to the southern boundary wall of Storey Garden.

Case Officer: null

Consultee Details

Name: Consultee Heritage Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: Havant.Heritage@havant.gov.uk

On Behalf Of: Conservation Officer

Comments

Heritage Team Leader Support

Following a site visit it is clear that the existing boundary wall is in a poor state of repair in a number of places. There is a distinct lean to the wall with a number of significant cracks running through the structure. It is therefore accepted that the works are required to the wall to ensure its stability and future.

The size of the new brick piers pay regard to the scale of the boundary wall and the materials used will ensure that they match existing materials on the site. The piers are also necessary to ensure the future structural integrity of the wall.

The other works include general repairs, removal of foliage and the replacement of copings. These works are entirely necessary and will ensure the restoration is in a sympathetic manor that will be in keeping with the existing structure.

In conclusion the proposals are appropriate and necessary to ensure the future of this important and historic wall. As I such I fully support the proposals.

Suggested Conditions:

- Material details which should include mortar details (prior to the commencement of work)