



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/18/00720

Our ref
PLAN-029830

Date
09/10/2019

Contact
Tel 0330 303 0119

Dear Sirs,

Proposal: Construction of 1No. 3 bed bungalows with access from London Road (approved 13.11.2018). Request to Discharge Condition Nos 3, 4, 5, 6, 8 and 10 (received 19.6.19).
Site: APP/18/00720: - 198 London Road, Waterloooville, PO7 7AN.

Thank you for your letter dated 20/09/2019.

The proposed means of foul and surface water disposal as shown in submitted drawing is satisfactory to Southern Water.

The proposed public sewer diversion is acceptable in principle, subject to obtaining Southern Water's approval under Section 185 of the Water Industry Act and subject to compliance with requirement to maintain the required standoff distance for sewers.

Southern Water have no comments to make on other conditions.

For any further queries please contact us at developerservices@southernwater.co.uk

Yours sincerely,

Tim Peacock-Bjurström
Technical Delivery Lead
Business Channels