

Registered Office:
Portsmouth Water Ltd
PO Box 8
Havant
Hampshire PO9 1LG

Tel: 023 9249 9888
Fax: 023 9245 3632
Web: www.portsmouthwater.co.uk

**CONSULTATION UNDER THE TOWN AND COUNTRY PLANNING
(DEVELOPMENT MANAGEMENT PROCEDURE ENGLAND) ORDER 2015**

Planning Application Reference:	APP/19/00909
Proposal:	Application for variation of condition 10 of planning permission APP/18/00478 and condition 9 of planning permission APP/19/00875 relating to revised piling arrangements.
Location:	Land adjacent to Fulflood Road, Havant
Date:	06 January 2020

Portsmouth Water have reviewed the further documentation to support the variation of condition 10 and the discharge of condition 9 of planning permission APP/19/00875.

With reference to our previous response on the variation of condition 10 dated 26th November 2019, we have no objections to the variation of condition 10 of planning permission APP/18/00478.

The applicant has provided further borehole information and details of the loads and max depth for the piles. The maximum depth of the piles will be 13m, Soiltechnics borehole information has confirmed by the installation of three boreholes on site that the chalk is at least 20.5m below the existing ground level which is at least 7.5m below the toe of the driven pile. Therefore the London Clay cover will not be breached and we would have no objections to the discharge of condition 9 of planning permission APP/19/00875.

Catchment Management Team
Portsmouth Water

catchment.management@portsmouthwater.co.uk