



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/20/00015

Our ref
PLAN-031604

Date
17/02/2020

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Demolition of retail unit and associated outbuildings and construction of a 3-storey building consisting of 1No retail unit with 4No one-bedroom flats fronting Elm Grove and a 3 storey, sheltered housing, building consisting of 19No one bedroom and 20No two bedroom assisted living accommodation with associated car parking and external works to the rear.

Site: APP/20/00015: - 108-110 Elm Grove, Hayling Island, PO11 9EN.

Thank you for your letter dated 27/01/2020.

Please find attached a plan of the sewer records showing the approximate position of a public foul sewer within the site. The exact position of the public foul sewer must be determined on site by the applicant before the layout of the proposed development is finalised.

Please note:

- No development or tree planting should be carried out within 3 metres of the external edge of the public gravity sewer without consent from Southern Water.
- No soakaway, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of a public sewer.
- All existing infrastructure should be protected during the course of construction works.

Furthermore, it is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.



Our initial investigations indicate that Southern Water can provide foul and surface water sewage disposal to service the proposed development. Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer. We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link <https://beta.southernwater.co.uk/infrastructure-charges>

The disposal of surface water from this development shall follow the hierarchy within Part H3 of Building Regulations:

- a) An adequate soakaway or some other adequate infiltration system.
- b) A water course.
- c) Where neither of the above is practicable: a sewer.

We request that should this application receive planning approval, the following condition is attached to the consent: "Construction of the development shall not commence until details of the proposed means of foul and surface water sewerage disposal have been submitted to, and approved in writing by, the Local Planning Authority in consultation with Southern Water."

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: developerservices@southernwater.co.uk

Yours faithfully,



Joff Edevane
Growth Planning Lead
Business Channels