

Houghton, Michelle

From: Le-Vallee, Helen
Sent: 02 January 2020 11:53
To: Havant Planning and Development Mailbox New
Cc: Haywood, Daphney
Subject: APP/19/01200

Site Address: Land adjacent to, 90-92 Hambledon Road, Waterlooville

Proposed Development: Replacement of the existing 14.7m column with a new 20m column along with additional cabinets and ancillary development.

Thank you for consulting the environmental protection team on the above planning application. In respect of noise we do not have objections to make in respect of this proposal, however if planning permission is granted we recommend the following condition is attached,

The Rating Level of the noise emitted from the plant shall not exceed the Background Sound Level at any time. The noise levels shall be determined at the nearest noise sensitive premises. The measurements and assessment shall be made according to British Standard 4142:2014+A1:2019.

Regards

Helen Le-Vallee
Environmental Health Officer
Direct Dial: 01730 234302



East Hampshire District Council
Penns Place, Petersfield
GU31 4EX

www.easthants.gov.uk
www.facebook.com/easthantsdc
www.twitter.com/easthantsdc

Your privacy matters, go to www.easthants.gov.uk/privacy-policy



Havant Borough Council
Public Service Plaza, Civic Centre Road
PO9 2AX

www.havant.gov.uk
www.facebook.com/havantboroughcouncil
www.twitter.com/havantborough

Your privacy matters, go to www.havant.gov.uk/privacy-policy