

Consultee Comments for Planning Application APP/19/01073

Application Summary

Application Number: APP/19/01073

Address: Fernwood House, 45-47 London Road, Cowplain, Waterloooville, PO8 8DH

Proposal: Second floor extension to form 8No. flats with associated refuse, cycle stores and parking.

Case Officer: Tina Pickup

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

The submitted plans do not show adequate access for either the fire service under Requirement B5 or for solid waste storage under Requirement H6 of the Building Regulation and the guidance given in the relevant Approved Documents