



**WATER
for LIFE**

from
**Southern
Water** 

Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/19/00513

Our ref
PLAN-030212

Date
07/11/2019

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Erection of three-storey multi-storey car park to provide 263 car parking spaces on existing Wellington Way car park.

Site: APP/19/00513: - Car Park, Wellington Way, Waterlooville PO7 7ED.

Thank you for your letter dated 17/10/2019.

The developer can discharge surface water flow no greater than existing levels as submitted in the drainage strategy and it is ensured that there is no overall increase in flows into the sewerage system. No additional flows other than currently received can be accommodated within exiting sewerage network.

Land uses such as general hardstanding that may be subject to oil/petrol spillages should be drained by means of oil trap gullies or petrol/oil interceptors.

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

For further advice, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119), www.southernwater.co.uk or by email at developerservices@southernwater.co.uk.

Yours sincerely,



Tim Peacock-Bjurström
Technical Delivery Lead
Business Channels