

ABMH		Page 1
1 The Grove Felpham West Sussex PO22 7EY	Woodcroft SW Design	
Date 07/08/2019 12:55 File FC2789 Woodcroft- sw de...	Designed by mh Checked by	
Micro Drainage	Network 2017.1.2	

Summary of Results for 60 minute 1 year Winter (Storm)

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
 Analysis Timestep Fine Inertia Status OFF
 DTS Status ON

		Water	Surcharged	Flooded		Pipe		
PN	US/MH Name	Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status
1.000	SWS13	67.147	-0.103	0.000	0.22		3.6	OK
1.001	SWS12	66.959	-0.115	0.000	0.12		4.9	OK
1.002	SWS11	65.681	-0.194	0.000	0.05		4.9	OK
2.000	SWS10.1	65.346	-0.179	0.000	0.09		6.4	OK
1.003	SWS10	64.715	-0.226	0.000	0.14		13.8	OK
1.004	SWS9	64.440	-0.214	0.000	0.18		13.7	OK
1.005	SWS8	63.109	-1.001	0.000	0.03		23.7	OK
3.000	Dummy	62.933	-0.225	0.000	0.00		0.0	OK
3.001	SW7.3	62.929	-0.225	0.000	0.00		0.0	OK
3.002	SW7.1	63.097	-0.778	0.000	0.00	0.0	1.2	OK
1.006	SWS7	63.097	-0.973	0.000	0.03		20.5	OK
1.007	SWS6	63.094	-0.966	0.000	0.04		19.9	OK
4.000	SWS5.1	65.277	-0.198	0.000	0.03		3.9	OK
1.008	SWS5	63.088	-0.958	0.000	0.03		28.1	OK
1.009	SWS4	63.078	-0.730	0.000	0.05		33.6	OK
1.010	SWS3	63.069	0.017	0.000	0.44		27.6	SURCHARGED
1.011	SWS2	62.797	-0.191	0.000	0.29		27.7	OK