



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/17/01339
Our Ref
PLAN-026182
Date
07/01/2019

Dear Sirs,

Proposal: Construction of two storey end of terrace dwelling (approved 14.02.18). Request to discharge condition No's 2,3,4,5 and 6 (14.12.18).
Site: 32 High Lawn Way, Havant, PO9 5BP.
APP/17/01339

Thank you for your letter of 18/12/2018.

The proposed public sewer protection measures are acceptable to Southern Water.

We are, however, not able to comment fully and provide recommendation regarding condition 4 relating to foul and surface water drainage as no site drainage layout is available for review. Please submit a detailed drainage layout plan, clearly indicating the on-site foul and surface water drainage and their relevant discharge points.

Southern Water would have no comments to make with regards to other conditions being subject of consultation.

Yours Sincerely

A handwritten signature in black ink, appearing to read "Marta Karpezo".

Marta Karpezo
Developer Services