

ABMH		Page 1
1 The Grove Felpham West Sussex PO22 7EY	Woodcroft SW Design	
Date 07/08/2019 13:51 File FC2789 Woodcroft- sw de...	Designed by mh Checked by	
Micro Drainage	Network 2017.1.2	

Summary of Results for 90 minute 1 year Winter (Storm)

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
 Analysis Timestep Fine Inertia Status OFF
 DTS Status ON

PN	US/MH Name	Water Surcharged Flooded			Pipe		Status
		Level (m)	Depth (m)	Volume (m³)	Flow / Cap. Overflow (l/s)	Flow (l/s)	
1.000	SWS13	67.141	-0.109	0.000	0.17	2.8	OK
1.001	SWS12	66.955	-0.119	0.000	0.09	3.8	OK
1.002	SWS11	65.678	-0.197	0.000	0.04	3.8	OK
2.000	SWS10.1	65.339	-0.186	0.000	0.07	4.9	OK
1.003	SWS10	64.706	-0.235	0.000	0.11	10.7	OK
1.004	SWS9	64.428	-0.226	0.000	0.14	10.7	OK
1.005	SWS8	63.088	-1.022	0.000	0.02	18.5	OK
3.000	Dummy	62.933	-0.225	0.000	0.00	0.0	OK
3.001	SW7.3	62.929	-0.225	0.000	0.00	0.0	OK
3.002	SW7.1	63.073	-0.802	0.000	0.00 0.0	1.0	OK
1.006	SWS7	63.073	-0.997	0.000	0.03	17.1	OK
1.007	SWS6	63.069	-0.991	0.000	0.03	16.7	OK
4.000	SWS5.1	65.274	-0.201	0.000	0.03	3.0	OK
1.008	SWS5	63.063	-0.983	0.000	0.03	23.8	OK
1.009	SWS4	63.049	-0.759	0.000	0.04	29.1	OK
1.010	SWS3	63.036	-0.016	0.000	0.41	26.0	OK
1.011	SWS2	62.794	-0.194	0.000	0.27	26.0	OK