

ABMH		Page 1
1 The Grove Felpham West Sussex PO22 7EY	Woodcroft SW Design	
Date 07/08/2019 12:54 File FC2789 Woodcroft- sw de...	Designed by mh Checked by	
Micro Drainage	Network 2017.1.2	

Summary of Results for 30 minute 1 year Winter (Storm)

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
 Analysis Timestep Fine Inertia Status OFF
 DTS Status ON

PN	US/MH Name	Water		Surcharged		Flooded		Pipe		Status
		Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Flow (l/s)			
1.000	SWS13	67.159	-0.091	0.000	0.33		5.5		OK	
1.001	SWS12	66.967	-0.107	0.000	0.18		7.1		OK	
1.002	SWS11	65.688	-0.187	0.000	0.07		7.1		OK	
2.000	SWS10.1	65.356	-0.169	0.000	0.14		9.8		OK	
1.003	SWS10	64.732	-0.209	0.000	0.20		20.1		OK	
1.004	SWS9	64.458	-0.196	0.000	0.26		20.2		OK	
1.005	SWS8	63.128	-0.982	0.000	0.04		33.0		OK	
3.000	Dummy	62.933	-0.225	0.000	0.00		0.0		OK	
3.001	SW7.3	62.929	-0.225	0.000	0.00		0.0		OK	
3.002	SW7.1	63.111	-0.764	0.000	0.00	0.0	1.8		OK	
1.006	SWS7	63.111	-0.959	0.000	0.04		27.0		OK	
1.007	SWS6	63.108	-0.952	0.000	0.05		25.8		OK	
4.000	SWS5.1	65.283	-0.192	0.000	0.05		6.0		OK	
1.008	SWS5	63.103	-0.943	0.000	0.04		35.0		OK	
1.009	SWS4	63.096	-0.712	0.000	0.06		40.4		OK	
1.010	SWS3	63.088	0.036	0.000	0.45		28.7		SURCHARGED	
1.011	SWS2	62.800	-0.188	0.000	0.30		28.7		OK	