

From: Mitchell, Harry
Sent: 25 October 2019 08:48
To: Haywood, Daphney <Daphney.Haywood@havant.gov.uk>
Subject: RE: Comments for Planning Application APP/18/00724

Hello Daphney,

The RPA of any tree is calculated (as set out in British standard 5837) by multiplying the diameter of the tree at breast height in meters by 12.

I disagree with the comments to propose a 'substantial' fence to prevent access to the billy trail. The construction of the fence will be detrimental to the landscape character, prevent the migration of wildlife and (depending on the type of fence) its construction could have an impact of the existing RPAs.

The tree warden suggests that a number of plots are redrawn as a result of off site trees I would not agree with the statement as the developer has offered an appropriate tree protection plan.

I still feel there is a lack of information in relation to the footpath the connects to the billy trail in terms of material spec and RPA mitigation strategy. I do not agree with fencing off this footpath for the same reasons noted about in relation to the substantial fence.

Kind regards,

Harry Mitchell CMLI

Landscape Architect

Havant Borough Council

Email -harry.mitchell@havant.gov.uk