



Department of Planning and Development  
Havant Borough Council  
Public Service Plaza  
Civic Centre Road  
Havant  
Hampshire  
PO9 2AX

Your ref  
APP/18/01211

Our ref  
PLAN-030108

Date  
30/10/2019

Contact  
Tel 0330 303 0119

Dear Sir/Madam,

**Proposal:** Demolition of existing two storey dwelling and erection of part two and part three storey dwelling, balcony and associated works. (Approved 05/07/2019). Request to discharge condition No/s 3 and 4 (07/10/2019).

**Site:** APP/18/01211: - 128A Park Avenue, Waterlooville, PO7 5DP.

Thank you for your letter dated 11/10/2019.

Southern Water shall have no objections to discharge condition 4 relating to foul and surface water drainage. An approval for the connection to the public sewer should be submitted under Section 106 of the Water Industry Act.

Please note the design of drainage should ensure that no land drainage or ground water is to enter public sewers network.

Southern Water has no comments to make on other conditions.

For any further queries please contact us at [developerservices@southernwater.co.uk](mailto:developerservices@southernwater.co.uk)

Yours sincerely,

Tim Peacock-Bjurström  
Technical Delivery Lead  
**Business Channels**

