

ABMH		Page 1
1 The Grove Felpham West Sussex PO22 7EY	Woodcroft SW Design	
Date 07/08/2019 12:50 File FC2789 Woodcroft- sw de...	Designed by mh Checked by	
Micro Drainage	Network 2017.1.2	

Summary of Results for 60 minute 1 year Summer (Storm)

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
 Analysis Timestep Fine Inertia Status OFF
 DTS Status ON

		Water	Surcharged	Flooded		Pipe		
	US/MH	Level	Depth	Volume	Flow /	Overflow	Pipe	
PN	Name	(m)	(m)	(m³)	Cap.	(l/s)	Flow	
							Status	
1.000	SWS13	67.153	-0.097	0.000	0.27		4.6	OK
1.001	SWS12	66.963	-0.111	0.000	0.15		6.0	OK
1.002	SWS11	65.685	-0.190	0.000	0.06		6.0	OK
2.000	SWS10.1	65.351	-0.174	0.000	0.12		8.1	OK
1.003	SWS10	64.724	-0.217	0.000	0.17		17.0	OK
1.004	SWS9	64.450	-0.204	0.000	0.22		17.0	OK
1.005	SWS8	63.112	-0.998	0.000	0.03		28.1	OK
3.000	Dummy	62.933	-0.225	0.000	0.00		0.0	OK
3.001	SW7.3	62.929	-0.225	0.000	0.00		0.0	OK
3.002	SW7.1	63.094	-0.781	0.000	0.00	0.0	1.2	OK
1.006	SWS7	63.094	-0.976	0.000	0.03		23.2	OK
1.007	SWS6	63.091	-0.969	0.000	0.04		22.7	OK
4.000	SWS5.1	65.280	-0.195	0.000	0.04		4.9	OK
1.008	SWS5	63.084	-0.962	0.000	0.04		31.1	OK
1.009	SWS4	63.075	-0.733	0.000	0.05		36.4	OK
1.010	SWS3	63.065	0.013	0.000	0.43		27.5	SURCHARGED
1.011	SWS2	62.797	-0.191	0.000	0.29		27.5	OK