

Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/16/00295
Our Ref
PLAN-025481
Date
03/12/2018

Dear Sirs,

Proposal: Veterinary practice, 4No. business units, parking and open storage yards. (Approved 30.05.17). Request to Discharge Condition No/s 4, 5, 6, 7 and 8. (22.06.17).
Site: Interbridges Site, New Brighton Road, Emsworth PO10 7PS.
APP/16/00295

Thank you for your letter of 29/11/2018

Southern Water would have no objections to discharge condition 8 relating to foul drainage.

The Council's Building Control officers/technical staff and the environment agency should be consulted regarding the discharge condition 8 for surface water disposal.

Please note: no soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of a public sewers.

Southern Water would have no comments to make with regards to other conditions being subject of consultation.

Yours sincerely



Claire Smith
Developer Services