

# Consultee Comments for Planning Application APP/19/00156

## Application Summary

Application Number: APP/19/00156

Address: Eastleigh House, Bartons Road, Havant, PO9 5NA

Proposal: Internal alterations to allow conversion from offices (class B1(a)) to form 6No one bed flats (C3 residential units).

Case Officer: Emma Chisnall

## Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

## Comments

Location of bin store does not appear to comply with Approved Document H6 regarding householders carrying waste

Flat 5 Room 15 (bedroom) is an inner room Compliance with Approved Document B to be considered

Building Regulation consent will be needed for this work