

Consultee Comments for Planning Application APP/19/00686

Application Summary

Application Number: APP/19/00686

Address: 56a Bracklesham Road, Hayling Island, PO11 9SJ

Proposal: Variation of Condition 2 of Planning Permission APP/17/01179 to vary approved plans (increase in footprint of property and addition of a third bedroom at first floor).

Case Officer: Lewis Oliver

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

The unprotected areas on both side elevations would exceed permitted limits as wooden cladding is being used. This will need to be changed to a fire resistant cladding.