



Hampshire County Council

*Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD*

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

<i>Enquiries to</i>	Vicki Westall	<i>My reference</i>	SWM/2019/0406
<i>Direct Line</i>	01962 846730	<i>Your reference</i>	APP/15/01235
<i>Date</i>	20 June 2019	<i>Email</i>	swm.consultee@hants.gov.uk

Dear Sir/Madam,

Re: Response 1 - Outline application for residential development for 43 residential dwellings with access off Woodcroft Lane and emergency access off Eagle Avenue with all other matters reserved. (Approved 05.08.2016). Request to discharge condition No/s 4 and 13 (12.04.2019). Request to discharge condition No. 12 (10.05.2019). Request to Discharge Conditions 5 and 10 (14.05.2019). at Land adjacent Woodcroft Primary school, Woodcroft Lane, Waterlooville, PO8 9QD

Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application in our role as statutory consultee on surface water drainage for major developments.

In order to assist applicants in providing the correct information to their Local Planning Authority for planning permission, Hampshire County Council has set out the information it requires to provide a substantive response at <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning>

Planning consent with conditions was previously given for this site and the following condition relates to that of the surface water drainage:

Condition 5:

No development hereby permitted shall commence until plans and particulars specifying the layout, depth and capacity of all foul and surface water drains and sewers proposed to serve the same, and details of any other proposed ancillary drainage works/plant (e.g. pumping stations) have been submitted to and approved in writing by the Local Planning Authority in consultation with Southern Water. Unless agreed otherwise in writing by the Local Planning Authority, the development hereby permitted shall not be brought into use

*Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI*

prior to the completion of the implementation of all such drainage provision in full accordance with such plans and particulars as are thus approved by the Authority.

Reason: To safeguard the amenities of the locality and ensure that all such drainage provision is constructed to an appropriate standard and quality and having due regard to policies and proposals CS16 and DM10 of the Havant Borough Local Plan (Core Strategy) 2011 and the National Planning Policy Framework.

The County Council has reviewed the following documents relating to the above planning condition:

- FC2789/07 Rev A Drainage Layout Over view
- FC2789/08 Rev A Drainage Layout 1 of 6
- FC2789/09 Rev A Drainage Layout 2 of 6
- FC2789/10 Rev A Drainage Layout 3 of 6
- FC2789/11 Rev A Drainage Layout 4 of 6
- FC2789/12 Rev A Drainage Layout 5 of 6
- FC2789/13 Rev A Drainage Layout 6 of 6

In order for us to provide a substantive response, the following information is required:

- Please provide drainage calculations for the system, including the permeable paving Formpave Calculations.
- Confirm if any of the access road is to be offered for adoption, and if so details on whether discussion has been undertaken with Highways and approval of the proposed drainage layout has been sought/obtained.

We require this further information before we can make a decision on whether to recommend to the Local Planning Authority that planning permission is granted.

As a statutory consultee, the County Council has a duty to respond to consultations within **21 days**. The 21 day period will not begin until we have received sufficient information to enable us to provide a meaningful response.

This is our **first response** to this consultation. If the above listed material is not supplied in full, a second response will be issued requesting the outstanding information. If the relevant documentation is not supplied following the second request we will recommend that the planning application be refused on the grounds of insufficient information.

Please ensure all data is sent to us via the relevant Local Planning Authority.

For guidance on providing the correct information, we recommend you use our **Surface Water Management Pre-application service** which provides clear

guidance on what is required for us to recommend that planning permission is granted and consider the works as best practise. For full details, please visit: <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning> and click on [pre-application advice request form](#).

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,



Flood and Water Management Team
Economy, Transport & Environment Department,
Hampshire County Council, 1st Floor, Ell Court West,
The Castle, Winchester, Hampshire SO23 8UD
Web: <http://www3.hants.gov.uk/flooding/watercourses.htm>

General guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:
<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

Works in relation to ordinary watercourses

PLEASE NOTE: *If the proposals include works to an ordinary watercourse, under the Land Drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.***

Information on ordinary watercourse consenting can be found at the following link <http://www3.hants.gov.uk/flooding/hampshireflooding/watercourses.htm>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

*For guidance on providing the correct information, we recommend you use our **Ordinary Watercourse Consents Pre-application service** and help avoid delays occurring at the formal application stage. A Pre-application service for Ordinary Watercourse Consents is available, allowing consents to go through in a smoother, often more timely manor. For full information please visit:*

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/WatercoursePreApplication>