

Consultee Comments for Planning Application APP/17/01243

Application Summary

Application Number: APP/17/01243

Address: 208 London Road, Waterlooville, PO7 7AN

Proposal: Erection of a single storey building to accommodate a nursery for a maximum number of 78 children including outside play area together with formation of car park, provision of boundary treatment and landscaping and alterations to existing pedestrian and vehicular accesses following demolition of existing house (Approved 24/05/2018). Request to Discharge Conditions 8, 9, 13, 14, 15, 17 and 18 (06.02.2019).

Case Officer: Rachel Ballam

Consultee Details

Name: Consultee Landscape Civil Engineering & Landscape Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: landscape@havant.gov.uk

On Behalf Of: Landscape Team

Comments

Planning Application APP/17/01243 208 London Road, Waterlooville, PO7 7AN

Erection of a single storey building to accommodate a nursery for a maximum number of 78 children including outside play area together with formation of car park, provision of boundary treatment and landscaping and alterations to existing pedestrian and vehicular accesses following demolition of existing house (Approved 24/05/2018). Request to Discharge Conditions 8, 9, 13, 14, 15, 17 and 18 (06.02.2019).

From a landscape perspective we have the following comments in relation to the discharge of conditions:

Condition 15

- There is insufficient information submitted in relation to the soft landscaping details to satisfy condition 15
- A detailed soft landscape scheme requiring submission of fully annotated plans at sufficient scale to identify species of individually planted trees, shrubs, hedges, marginal, bulbs and any areas of turfing / seeding. Planting areas should show the locations of different single species groups in relation to one another, and the locations of any individual specimen shrubs. Other information shall include plant specification schedules, comprising plant size, number and density.

Condition 16

- There is insufficient information submitted in relation to the boundary details to satisfy condition 16
- Boundary details requiring submission of fully annotated plans at sufficient scale showing the locations of existing, retained and proposed new boundary treatments, with scaled elevation drawings to show height, design, materials, type and colour of proposed new walling / fencing or other type of enclosure and associated gates.

Condition 17

- There is insufficient information submitted in relation to the hard surfacing details to satisfy condition 17
- Hard landscape details requiring submission of fully annotated plans at sufficient scale that comprise a range of coloured and textured surfacing treatments, which identify:
 - finished levels
 - hard surfacing material type / product reference and colour
 - laying bond
 - edging or threshold detail / type
 - retaining structures or steps

Kind regards,

Harry Mitchell
Landscape Architect
Havant Borough Council
Email harry.mitchell@havant.gov.uk