

Subject: APP/18/00198

As per our earlier discussion, I am satisfied with the proposed condition related to the mitigation measures in the form of an extended 3.5 metre acoustic fence with return legs on the entrance way to the scaffold companies yard, as per the drawing depicted on page 16 of 34 of the acoustic report, Ref: SA-4697-3 / Report date: October 2018, and the amended drawing LCW4 dated 13 June 2019 together with Item A of the memo attached to this drawing. There is also no need to replicate the Condition 2 as laid out in my memo dated 11/10/2018.

Kind regards

Mark Moss

Regulatory Officer

Environmental Health Pollution

Havant Borough Council

Public Service Plaza, Civic Centre Road, Havant PO9 2AX