



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/17/00511
Our Ref
PLAN-026634
Date
12/02/2019

Dear Sirs,

Proposal: Proposed Gas fuelled Capacity Mechanism embedded generation plant to support the National Grid. (23.11.17). Request to discharge condition no's 3,4,5 & 6 (14.01.19).

Site: Hermitage Park, Harts Farm Way, Havant, PO9 1HS.
APP/17/00511

Thank you for your letter of 22/01/2019.

Southern Water would not recommend discharge of conditions 3 and 4. The submitted information demonstrates contradictory layout of the site. Please clarify the development layout which is currently under assessment.

The proposals to divert public foul sewer and the construction of underground services within the standoff distance of public critical sewer shall be agreed under Section 185 of the Water Industry Act shall be carried out strictly in accordance and as agreed with Southern Water.

Yours Sincerely

A handwritten signature in black ink, appearing to read "Marta Karpezo".

Marta Karpezo
Developer Services