

From: Karpezo, Marta <Marta.Karpezo@southernwater.co.uk>
Sent: 08 July 2019 11:58
To: Glover, Gill <Gill.Glover@havant.gov.uk>
Subject: RE: APP/18/00918 9A Lovedean Lane, Waterloooville

Dear Gill

From the provided drawings it is not clear and sufficiently proven that the required distance will be maintained. The construction shall be no closer than 500mm from the external edge of the manhole located within the site.

Please note that the sewer shall be exactly located on site by the applicant.

In order to ensure that the extension is built in accordance with requirements:

- it can be ensured and supervised by Building Control (the location, size, depth and condition of sewer to be determined by applicant)
- the applicant may apply under Declaration of Works application process for approval of these works (the location, size, depth and condition of sewer to be determined by applicant)
 - due to length of the sewer tor be built close to.
<https://developerservices.southernwater.co.uk/DeclarationOfWorks/ApplicationForm>
- the applicant may apply under Build Close to Public Sewer application process for approval of these works (the location, size, depth and condition of sewer to be determined by Southern Water)
 - due to length of the sewer tor be built close to.
<https://developerservices.southernwater.co.uk/BuildOver/ApplicationForm>

Kind Regards

Marta Karpezo
Planning Coordinator
for Hants and IOW

T. 0330 303 0119
southernwater.co.uk

