

Ms R. Ballam
Planning Services
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Date: 8th March 2019
Enquiries to: Stuart York
Direct Line: 023 8047 8566
Our reference: app/19
Your reference: APP/15/01435

Dear Ms Ballam,

LAND SOUTH OF BARTONS ROAD, HAVANT

Thank you for your letter of the 8th February 2019 and the opportunity to comment upon the application. Having considered the application I have the following comments to make with reference to crime prevention.

Discharge of condition 10, I have presumed that I am to comment upon the lighting proposals contained within this condition.

I would have expected the lighting plan to show a uniformity value of between 0.40 and 0.25, however, with the proposed scheme the uniformity value is often below this value, consistently being between 0.22 and 0.24.

The area to the front of Plots 87 to 92 appears to have no lighting.

The overall lighting plan should be modified to provide a uniformity value of at least 0.25 throughout, and lighting should be placed to the front of plots 87 to 92.

If I can be of any further assistance please do not hesitate to contact me.

Yours sincerely,

S York
Designing Out Crime Officer

DISCLAIMER

This survey is based on information supplied by yourself and the current crime trends. I can only give a view on what measures might reduce the risk of crime and there can be no guarantee that the measures will prevent crime. The advice is given free with no intention of creating a contract. Neither the Home Office or the Police and Crime Commissioner for Hampshire take any other legal responsibility for the advice given.