

Consultee Comments for Planning Application APP/19/00067

Application Summary

Application Number: APP/19/00067

Address: 1A Haven Road, Hayling Island, PO11 9QX

Proposal: Replacement of caravan with 1No two bedroom chalet bungalow (previously approved on Appeal ref APP/12/00273).

Case Officer: Emma Chisnall

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

Provision of ground floor wc to be provided under Approved Document M requirements

Location of solid waste storage to be shown so as complying with Approved Document H requirements

North elevation boundary should be at least 1m from face of property regarding unprotected areas issues under Approved Document B requirements

Building Regulation application will be required for this work