




**WATER  
for LIFE**

from  
**Southern  
Water** 

Department of Planning and Development  
Havant Borough Council  
Public Service Plaza  
Civic Centre Road  
Havant  
Hampshire  
PO9 2AX

Your ref

APP/16/00774

Our ref

PLAN-028318

Date

12/06/2019

Contact

Tel 0330 303 0119

Dear Sirs,


**Proposal: Erection of 147 dwellings with associated parking, access, landscaping, and surface water drainage, pumping station, sub station and signalised junction onto Havant Road (amended scheme). (Approved 29/06/2018). Request to discharge condition No/s 3, 4, 9, 12, 13, 14, 16, 17, 18, 20, 22 and 24 (15.11.2018). Request to discharge conditions 5, 9 & 10 (30.4.19)**

**Site: Land north of Havant Road and west of Selangor Ave, Emsworth, PO10 7LG.**  
**APP/16/00774**

Further to our correspondence dated 30<sup>th</sup> May 2019 regarding the above development site please find attached our comments in relation to condition 22 (referenced date 15/11/2018)

Southern Water has no objection to the proposed surface water (flow rate of 12.3 l/s) been connected to manhole reference 0950. Therefore, Southern Water would have no objection to the discharge of condition 22.

Yours Sincerely



Stuart Ward