

HAVANT BOROUGH COUNCIL

Town & Country Planning Act 1990

Consultation on Planning Application

MEMORANDUM

From: Environmental Health **To:** Development Control

Our Ref: CONS/19/01187 **Your Ref:** APP/19/00154

EH Case Officer Extn: 44 6666 **Date:** 27 June 2019

DC Case Officer: Gill Glover

DC Case Officer Extn: 6534

Application Number: APP/19/00154

Site Address: Unit 10, Dukes Walk, Waterloooville, PO7 7HS

Proposed Development: A request has been made to discharge the following condition(s) on the above application:
Condition 3:

.
Any views you wish to make should be returned to me no later than 21 days from the date of this email.

Observations / Comments:

I refer to the above request under the Town & Country Planning Acts passed to this Service for comment.

I have read the extractor unit documentation provided , and have also discussed the proposed extractor unit to be employed with the applicant, and can comment, as follows:

The extractor unit is fitted with washable aluminium filters and replaceable charcoal filters. As this unit is not to be ducted to the external air and will rely only on the filters provided (this has been verified with the applicant today), I am satisfied that Condition 3 can now be discharged.

If you should require clarification of any of the above, please do not hesitate to contact me.

Mr. Mark Moss

Regulatory Officer, Environmental Health