

Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: southernwaterplanning@atkinsglobal.com

Your Ref

APP/17/01293

Our Ref

PLAN-023340

Date

25/06/2018

Dear Sirs,

Proposal: Construction of 4No. 3 bed dwellings following demolition of existing dwelling. (Approved 8/5/18). Request to discharge condition No/s 3, 4, 5, 6, 8, 10, 12 and 13 (16.05.18).

Site: 42 Hulbert Road, Havant, PO9 3TF.

APP/17/01293

Thank you for your letter of 06/06/2018.

Southern Water would not recommend discharge of condition 5 relating to foul disposal. No complete foul drainage layout up to the final connection point has been provided for assessment. Please submit a detailed drainage layout plan, clearly indicating the on-site foul drainage and the relevant discharge point.

Southern Water would have no comments to make with regards to other conditions being subject of consultation.

Yours sincerely

A handwritten signature in black ink, appearing to read "Santa Lopez".

Developer Services

