

Mr A Vanags
Manhire Surveyors LLP
60A North Street
Chichester
West Sussex
PO19 1NB

8 January 2019
Our Ref: D1323

Dear Andrew,

RE: INTERBRIDGES, NORTH STREET, EMSWORTH, CHICHESTER PO10 7PH

Further to comments received from Havant Borough Council dated Monday 10 December 2018, we have revised drawing 2018-D1323-302C - 'Drainage Layout' and have the following comments to make in response to the points raised.

We have revised our proposals to ensure that there is clearance of 600mm from the invert of the proposed surface water rising main and the crown of the critical high-pressure gas main.

Havant Borough Council should be made aware that the site layout has been developed taking into account the high-level gas main – with SGN having been consulted, and that intrusive on-site investigation has been undertaken (by others) to confirm line and level of this apparatus. It should also be noted that SGN has agreed to 2 No. vehicular/service crossing points in relation to the gas main, one of which the proposed surface water rising main is to pass over/through.

In addition to this, and in relation to the second point raised by Havant Borough Council, the line of the surface water rising main has been slackened, to reduce the 90-degree bend exiting the pump chamber shown on the previous drawing revision.

Please also find attached the outstanding Maintenance Schedule, which details the frequency at which the required maintenance activities should be undertaken, as requested.

We trust that the above addresses the outstanding points raised by Havant Borough Council, however, should you find that any additional input is required from ourselves, please do not hesitate to get back in touch where we will be happy to assist, where possible.

Yours sincerely

A handwritten signature in black ink, appearing to read 'M. Akmenkalns', written in a cursive style.

Mark Akmenkalns
Director