



*Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD*

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

<i>Enquiries to</i>	Vicki Westall	<i>My reference</i>	SWM/2018/0157
<i>Direct Line</i>	01962 846730	<i>Your reference</i>	APP/18/00071
<i>Date</i>	24 August 2018	<i>Email</i>	SWM.consultee@hants.gov.uk

Dear Sir/Madam,

Proposed new factory and wood chip store and associated works for B1, B2 and B8 use. at Plot 2, Hermitage Park, Harts Farm Way, Havant, PO9 1FA

Thank you for consulting us on the above planning application. Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application as our statutory consultee role in relation to surface water drainage for major development.

Surface Water Drainage

We have reviewed the following information in relation to the planning application:

- Drainage Impact Assessment and Drainage Strategy rev1.1

The proposals for surface water drainage meet the current standards/best practice in relation to surface water drainage.

Please see below for further general guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

*Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI*

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Kind Regards

The Flood and Water Management Team
EII Court West, 1st Floor
Winchester
Hampshire
SO23 8UJ

T: 01962 846730

E: swm.consultee@hants.gov.uk