

From: Dave Wilson [<mailto:mail@surveycloud.co.uk>]

Sent: 05 September 2018 11:40

To: Chisnall, Emma

Subject: Re: Extension of time form- APP/18/00632

Hello Emma,

Please see attached Revision A drawing addressing your concerns contained in your below email dated 03/09/18.

We have designed a hidden gutter to the side extension removing the overhang concern. All additional water draining into existing outfalls with no excess water run off impacting the neighbour.

The two ground floor windows are proposed to be fixed units.

Hope this addresses your final concerns. Please do let me know if you require further details/clarification.

Best Regards

Dave Wilson BSc (Hons)

SurveyCloud Ltd

Phone 07900 808 808

Office 01730 262 485

mail@surveycloud.co.uk

www.surveycloud.co.uk

On 3 Sep 2018, at 09:53, Chisnall, Emma <Emma.Chisnall@havant.gov.uk> wrote:

no excess water run off impacts the neighbour.