



Registered Office:
Portsmouth Water Ltd
PO Box 8
Havant
Hampshire PO9 1LG

Tel: 023 9249 9888
Fax: 023 9245 3632
Web: www.portsmouthwater.co.uk

**CONSULTATION UNDER THE TOWN AND COUNTRY PLANNING
(DEVELOPMENT MANAGEMENT PROCEDURE ENGLAND) ORDER 2010**

Planning Application Reference:	APP/18/01206
Proposal:	Erection of 8no. Supported Living Apartments with ancillary social space and associated car parking
Location:	42 Bedhampton Hill, Havant, PO9 3JW
Date:	18 December 2018

Portsmouth Water have reviewed the application for the erection of 8no. Supported living apartments with ancillary social space and associated car park at 42 Bedhampton Hill, Havant and have the following comments.

The site is situated 84 metres south of Source Protection Zone 1 for Havant and Bedhampton springs- an essential Public Water Supply source.

The surface water drainage strategy for the site is discharge via soakaway- Portsmouth Water require further details on the type of soakaway proposed and the location layout of these drainage features. The foul water drainage strategy for the site is discharge to an existing main sewer drainage system, providing there are no surface and/or foul discharges off site that could potential impact the underlying Chalk Aquifer Portsmouth Water have no further comments on this application.

Catchment Management Team
Portsmouth Water

catchment.management@portsmouthwater.co.uk