

Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: southernwaterplanning@atkinsglobal.com

Your Ref

APP/16/00060

Our Ref

PLAN-022928

Date

22/05/2018

Dear Sirs,

Proposal: Request to Discharge Conditions 5 (03.05.18). (Demolition of existing buildings (shop, 1no. flat, workshop, associated compound and 2no. dwelling houses) and construction of 18no. new build flats and 3no. shop units (planning class A1) with associated bin store, cycle store, vehicle parking and landscaping (approved 29.09.17). Request to Discharge Conditions 3, 5, 6, 7, 9, 10 (17.10.17).

Site: 36, 38 and 40 Station Road and 1 West Lane, Hayling Island, PO11 0EQ.
APP/16/00060

Thank you for your letter of 25/10/2017

Southern Water would not recommend discharge of condition 5 relating to surface water disposal.

No assessment is available for review of the impact of the proposed surface water run off disposal on the public surface water network and the impact on increase in risk of flooding in the area.

The applicant's surface water drainage proposals shall indicate the final discharge point to the public sewer.

Yours sincerely



Developer Services