



*Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD*

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

<i>Enquiries to</i>	Vicki Westall	<i>My reference</i>	SWM/2018/0808
<i>Direct Line</i>	01962 846730	<i>Your reference</i>	APP/18/00478
<i>Date</i>	10 October 2018	<i>Email</i>	swm.consultee@hants.gov.uk

Dear Sir/Madam,

**Application for variation of Condition 15 of Planning Permission
APP/15/01233 relating to internal layout, fenestration layout and main
entrance (approved 16.8.18). Request to discharge condition No. 6
(3.09.18). Request to discharge condition No's 3, 4, 9, 11 and 14
(10.09.18). at Land adj Fulflood Road, Havant**

Thank you for consulting us on the above planning application. Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application as our statutory consultee role in relation to surface water drainage for major development.

Works in relation to ordinary watercourses

PLEASE NOTE: If the proposals include works to an ordinary watercourse, under the Land drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.**

Information on ordinary watercourse consenting can be found at the following link <http://www3.hants.gov.uk/flooding/hampshireflooding/watercourses.htm>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

A Pre-application service for Ordinary Watercourse Consents is available, allowing consents to go through in a smoother, often more timely manor. For full information please visit:

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/WatercoursePreApplication>

*Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI*

Surface Water Drainage

Planning consent with conditions was previously given for this site and the following condition relates to that of the surface water drainage:

Condition 9

No development hereby shall commence until details of the proposed means of surface water disposal have been submitted to, and approved in writing by, the Local Planning Authority. Proposals shall be in accordance with the principles of CIRIA C753 section 26.7 (SUDS Manual, 2015; Managing pollution risks), and where appropriate shall include a schedule of operational and preventative maintenance for surface water drainage structures, pumps or separators required either for the proper operation of the system to its design flow rates or for the effective retention of pollutants to prevent downstream release. Parties responsible for observing the maintenance schedule shall be clearly identified. All details Submitted in accordance with this condition shall be implemented as approved.

We have reviewed the following information in relation to the discharge of condition 9:

- *Drainage Layout – WMP-AKSW-XX-XX-DR-C-92005-P01*
- *Southern Water Response dated 02/10/2018*

We require further information/clarification on the proposals in order to provide a response:

- The Southern Water Response dated 02/10/2018 confirms that they would not accept the permeable paving area to be above or within 5m of the public sewer. The drawing provided currently does not conform to Southern Waters comments and shows the permeable paving over the public sewer.
- If not using infiltration for drainage - Existing and proposed run-off rate calculations completed according to a suitable method such as IH124 or FEH. Information is available from UK Sustainable Drainage: Guidance and Tools. Calculations must show that the proposed run off rates do not exceed the existing run-off rates. This must be shown for a one in one year event plus climate change and a one in one hundred year event plus climate change.
- If not using infiltration for drainage - Existing and proposed run-off volume calculations completed according to a suitable method such as IH124 or FEH. Calculations must show that, where reasonably practical, runoff volume should not exceed the greenfield runoff volume for the same event. This must be shown for a 1 in 100 year, 6 hour rainfall event

- Maintenance regimes of entire surface water drainage system including individual SuDS features, including a plan illustrating the organisation responsible for each element. Evidence that those responsible/adopting bodies are in discussion with the developer. For larger/phased sites, we need to see evidence of measures taken to protect and ensure continued operation of drainage features during construction.
- Evidence that enough storage/attenuation has been provided without increasing the runoff rate or volume. This must be shown for a 1 in 100 year plus climate change event. Please provide Micro Drainage calculations.
- Exceedance flows are considered in the event of the pipe being non-operational. Evidence that Exceedance flows and runoff in excess of design criteria have been considered - calculations and plans should be provided to show where above ground flooding might occur and where this would pool and flow.
- Evidence that Urban Creep has been considered in the application and that a 10% increase in impermeable area has been used in calculations to account for this.

We recommend that these issues are addressed before planning permission is granted. For guidance on solving these issues, we recommend you use our Surface Water Management Pre-application service which will provide clear guidance on what information is required to allow your application to be returned to the Local Planning Authority with no issues. For full details, please visit:

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning> and click on [pre-application advice request form](#).

No development shall take place until a detailed surface water drainage strategy has been provided to the Lead Local Flood Authority.

Please see below for further general guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Kind regards,

The Flood and Water Management Team
EII Court West, 1st Floor
Winchester
Hampshire
SO23 8UJ

T: 01962 846730

E: swm.consultee@hants.gov.uk