

Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: southernwaterplanning@atkinsglobal.com

Your Ref
APP/18/00601
Our Ref
PLAN-023843
Date
06/08/2018

Dear Sirs,

Proposal: Single storey side and rear extension, following demolition of single storey element forming existing kitchen and part removal of front stone wall dividing no 23 and 25 Lymbourn Road.

Site: 25 Lymbourn Road, Havant, PO9 2SL
APP/18/00601

Thank you for your letter of 16/07/2018.

Please find attached a plan of the sewer records showing the approximate position of a public foul sewer within the site. The exact position of the public sewer must be determined on site by the applicant before the layout of the proposed development is finalised.

If planning permission were to be granted, Southern Water (as the statutory sewerage undertaker) would request that the Council (as the Building Control Authority) refuse Building Regulations approval of the proposed layout on the grounds that building over the public sewer, public manhole and change of direction cannot be permitted. Southern Water requests that this application is not determined until such time as the applicant produces a suitable development and drainage layout.

Please note:

1. No construction works parallel to the sewer within 500mm (in plan).
2. Where within three metres, foundations to be taken down 150mm below the invert level.

3. Sewer to be bridged by PCC lintel to Building Control specifications (where applicable).
4. Replacement work to be carried out in approved material (not PVC).
5. No internal public manholes.

In order to protect drainage apparatus, Southern Water requests that if consent is granted, a condition is attached to the planning permission. For example "The developer must advise the local authority (in consultation with Southern Water) of the measures which will be undertaken to protect/ divert the public sewers, prior to the commencement of the development."

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk.

Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer. We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link <https://beta.southernwater.co.uk/infrastructurecharges>

The applicant has not stated details of the proposed means of disposal of surface water from the site. This should not involve disposal to a public foul sewer.

It is the responsibility of the developer to make suitable provision for the disposal of surface water. Part H3 of the Building Regulations prioritises the means of surface water disposal in the order

- a Adequate soakaway or infiltration system
- b Water course
- c Where neither of the above is practicable sewer

We request that should this application receive planning approval, the following condition is attached to the consent: "Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to, and approved in writing by, the Local Planning Authority in consultation with Southern Water."

Yours sincerely

A handwritten signature in black ink, appearing to be 'CS' or similar, written in a cursive style.

Claire Smith
Developer Services